



LISTING INFORMATION OF

**Skamol A/S - SkamoDoor® 45-90 Min Positive Pressure Cat.
A Mineral Core Fire Door**

SPEC ID: 14692

Skamol A/S
Hasselager Centervej 1
Viby, NA 8260
Denmark

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

LISTING INFORMATION

PRODUCT TYPE & MODEL NUMBERS

Mineral Core Type, Swinging flush door for installation in and up to 45, 60 and 90 minute locations. For use in listed (3-sided) 16-gauge welded steel frames meeting UL63 or as per frame manufacturer's listing(s).

Configuration	Maximum Size
Single Swing	4'0" x 8'0"
Standard Pairs	8'0" x 8'0"
Double Egress Pairs	Not Allowed
Door with Transom (Overall Size)	4'0" x 8'0"

Limitations*:

Mortise or Cylindrical Latches with maximum 5" backset / Mortise Fire Exit Devices / Surface-Mounted Vertical Rod Fire Exit Devices / Rim-Type Fire Exit Devices / Concealed Vertical Rod Fire Exit Devices / Deadbolts / Surface Bolts / Automatic Flush Bolts / Surface-Mounted Closers / Concealed Closer Arms (45 and 60) / Surface-Mounted Protection Plates / Plant-Ons / Viewer / Louver / Vision Light Kit – Maximum 1296 sq. in. (45 Minutes only) / Vision Light Kit – Maximum 100 sq. in. (60 and 90 Minutes) / Surface-Mounted or Concealed Door Bottoms / Metal Edge or Astragal Not Required up to 60 Minutes / 5" Metal Edge Required on CVR / 1" Metal Edge Required on 90 Minute Pair with 3 Point Latch / Temperature Rise - 250°F at 30 Minutes / Reveals and Inlays.

* See manufacturer's installation instructions for additional information on Smoke and Draft Control, size restrictions, and limitations.

Attribute	Value
Criteria	UL 10(b) Revision 1 (2009)
Criteria	CAN / ULC S104 (2015)
Criteria	UL 10(c) (2016)
Criteria	NFPA 252 (2017)
CSI Code	08 10 00 Doors and Frames
Fire Resistance	45 Min Neutral Pressure
Fire Resistance	60 Min PP Category A Door
Fire Resistance	90 Min Neutral Pressure
Fire Resistance	90 Min PP Category A Door
Fire Resistance	45 Min PP Category A Door
Fire Resistance	60 Min Neutral Pressure
Intertek Services	Certification
Listed or Inspected	LISTED
Listing Section	CATEGORY A - DOORS - NO ADDITIONAL EDGE-SEALING SYSTEM REQUIRED
Report Number	3074869, 3186655, G104382352

Spec ID 14692
Swing Single Swing
Swing Standard Pairs
Temperature Rise @ 30 Min = 250° F MAX Where Lites Do Not Exceed 100 IN2
Verification Testing No